

PAT TEST SPECIALIST

CERTIFICATE OF ELECTRICAL TESTING

This certifies that

ABC inflatable's, 20 Simon Avenue, Margate, Kent, CT9 3DT

Had their PAT testing done on


DATE OF TEST 30/11/22

The electrical appliances on these premises have been inspected and tested for electrical safety to the requirements of the electricity at work regulations

Retest date 30/11/23

Tested by Jason Cairns

PAT TEST SPECIALIST
Portable Appliance Testing
1 Quex View Road, Birchington
Kent, CT7 0DZ
Phone: **01843 842762** Mobile: **07725460276**
www.pattesting-kent.com



Client	Location	ID	Description	Test Date	Visual	Continuity	Insulation	Leakage	VA	Polarity	Test Overall Status
ABC INFLATABLES	CT93DT	1	AC LEAD	30/11/2022	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT93DT	2	AC LEAD	30/11/2022	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT93DT	3	BANE-MARI	30/11/2022	Pass		80.9 MΩ	< 0.10 mA	931VA		Pass
ABC INFLATABLES	CT93DT	4	BANE-MARI	30/11/2022	Pass		37.37 MΩ	< 0.10 mA	920VA		Pass
ABC INFLATABLES	CT93DT	5	16A LEAD	30/11/2022	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT93DT	6	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	0.11 mA	1433VA		Pass
ABC INFLATABLES	CT93DT	7	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	< 0.10 mA	1377VA		Pass
ABC INFLATABLES	CT93DT	8	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	< 0.10 mA	1403VA		Pass
ABC INFLATABLES	CT93DT	9	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	< 0.10 mA	1410VA		Pass
ABC INFLATABLES	CT93DT	10	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	< 0.10 mA	1354VA		Pass
ABC INFLATABLES	CT93DT	11	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	0.11 mA	774VA		Pass
ABC INFLATABLES	CT93DT	12	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	< 0.10 mA	1409VA		Pass
ABC INFLATABLES	CT93DT	13	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	< 0.10 mA	1627VA		Pass
ABC INFLATABLES	CT93DT	14	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	< 0.10 mA	1295VA		Pass
ABC INFLATABLES	CT93DT	15	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	0.12 mA	1905VA		Pass
ABC INFLATABLES	CT93DT	16	16A LEAD	30/11/2022	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT93DT	17	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	< 0.10 mA	1312VA		Pass
ABC INFLATABLES	CT93DT	18	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	< 0.10 mA	1363VA		Pass
ABC INFLATABLES	CT93DT	19	BLOWER	30/11/2022	Pass	0.09 Ω	> 99.9 MΩ	< 0.10 mA	1504VA		Pass
ABC INFLATABLES	CT93DT	20	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	< 0.10 mA	1441VA		Pass
ABC INFLATABLES	CT93DT	21	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	< 0.10 mA	1407VA		Pass
ABC INFLATABLES	CT93DT	22	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	< 0.10 mA	1365VA		Pass
ABC INFLATABLES	CT93DT	23	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	< 0.10 mA	1344VA		Pass
ABC INFLATABLES	CT93DT	24	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	< 0.10 mA	1440VA		Pass
ABC INFLATABLES	CT93DT	25	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	< 0.10 mA	1363VA		Pass
ABC INFLATABLES	CT93DT	26	BLOWER	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	< 0.10 mA	1790VA		Pass
ABC INFLATABLES	CT93DT	27	BLOWER	30/11/2022	Pass		> 99.9 MΩ	< 0.10 mA	496VA		Pass
ABC INFLATABLES	CT93DT	28	BLOWER	30/11/2022	Pass		1.19 MΩ	1.04 mA	1681VA		Pass
ABC INFLATABLES	CT93DT	29	BLOWER	30/11/2022	Pass		17.37 MΩ	0.14 mA	2310VA		Pass
ABC INFLATABLES	CT93DT	30	BLOWER	30/11/2022	Pass		5.82 MΩ	0.38 mA	2183VA		Pass
ABC INFLATABLES	CT93DT	31	BLOWER	30/11/2022	Pass		7.07 MΩ	0.76 mA	1713VA		Pass
ABC INFLATABLES	CT93DT	32	16A LEAD	30/11/2022	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT93DT	33	HEATER	30/11/2022	Pass	< 0.01 Ω	4.11 MΩ	< 0.10 mA	1429VA		Pass
ABC INFLATABLES	CT93DT	34	BLOWER	30/11/2022	Pass		1.69 MΩ	0.66 mA	2567VA		Pass
ABC INFLATABLES	CT93DT	35	EXT LEAD	30/11/2022	Pass	0.4 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	36	EXT LEAD	30/11/2022	Pass	0.35 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	37	EXT LEAD	30/11/2022	Pass	0.31 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	38	EXT LEAD	30/11/2022	Pass	0.34 Ω	> 99.9 MΩ			Normal	Pass

ABC INFLATABLES	CT93DT	39	EXT LEAD	30/11/2022	Pass	0.33 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	40	EXT LEAD	30/11/2022	Pass	0.34 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	41	EXT LEAD	30/11/2022	Pass	0.43 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	42	EXT LEAD	30/11/2022	Pass	0.31 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	43	EXT LEAD	30/11/2022	Pass	0.33 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	44	EXT LEAD	30/11/2022	Pass	0.4 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	45	EXT LEAD	30/11/2022	Pass	0.75 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	46	EXT LEAD	30/11/2022	Pass	0.8 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	47	EXT LEAD	30/11/2022	Pass	0.76 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	48	EXT LEAD	30/11/2022	Pass	0.32 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	49	BLOWER	30/11/2022	Pass		19.55 MΩ	0.12 mA	2362VA		Pass
ABC INFLATABLES	CT93DT	50	BLOWER	30/11/2022	Pass		32.62 MΩ	0.18 mA	2324VA		Pass
ABC INFLATABLES	CT93DT	51	BLOWER	30/11/2022	Pass		3.68 MΩ	1.24 mA	2124VA		Pass
ABC INFLATABLES	CT93DT	52	BLOWER	30/11/2022	Pass		18.71 MΩ	0.13 mA	1010VA		Pass
ABC INFLATABLES	CT93DT	53	16A LEAD	30/11/2022	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT93DT	54	16A LEAD	30/11/2022	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT93DT	55	BLOWER	30/11/2022	Pass		6.54 MΩ	0.33 mA	996VA		Pass
ABC INFLATABLES	CT93DT	56	BLOWER	30/11/2022	Pass		15.99 MΩ	0.19 mA	983VA		Pass
ABC INFLATABLES	CT93DT	57	BLOWER	30/11/2022	Pass		4.3 MΩ	0.36 mA	1021VA		Pass
ABC INFLATABLES	CT93DT	58	16A LEAD	30/11/2022	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT93DT	59	16A LEAD	30/11/2022	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT93DT	60	BLOWER	30/11/2022	Pass		14.11 MΩ	0.25 mA	956VA		Pass
ABC INFLATABLES	CT93DT	61	BLOWER	30/11/2022	Pass		8.95 MΩ	0.22 mA	1009VA		Pass
ABC INFLATABLES	CT93DT	62	BLOWER	30/11/2022	Pass		32.25 MΩ	0.28 mA	2092VA		Pass
ABC INFLATABLES	CT93DT	63	BLOWER	30/11/2022	Pass		12.5 MΩ	0.32 mA	2173VA		Pass
ABC INFLATABLES	CT93DT	64	BLOWER	30/11/2022	Pass		24.99 MΩ	0.11 mA	2322VA		Pass
ABC INFLATABLES	CT93DT	65	16A LEAD	30/11/2022	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT93DT	66	16A LEAD	30/11/2022	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT93DT	67	16A LEAD	30/11/2022	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT93DT	68	16A LEAD	30/11/2022	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT93DT	69	EXT LEAD	30/11/2022	Pass	0.09 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	70	EXT LEAD	30/11/2022	Pass	0.11 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	71	EXT LEAD	30/11/2022	Pass	0.24 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	72	16A EXT LEAD	30/11/2022	Pass	0.06 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	73	EXT LEAD	30/11/2022	Pass	0.19 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	74	16A EXT LEAD	30/11/2022	Pass	0.07 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	75	16A LEAD	30/11/2022	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT93DT	76	16A LEAD	30/11/2022	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT93DT	77	16A LEAD	30/11/2022	Pass		> 99.9 MΩ				Pass

ABC INFLATABLES	CT93DT	78	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	79	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	80	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	81	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	82	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	83	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	84	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	85	16A ADAPTOR	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	86	16A ADAPTOR	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	87	16A ADAPTOR	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	88	16A ADAPTOR	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	89	16A ADAPTOR	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	90	16A ADAPTOR	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	91	16A EXT LEAD	30/11/2022	Pass	0.07 Ω	> 99.9 MΩ	Normal Pass
ABC INFLATABLES	CT93DT	92	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	93	16A ADAPTOR	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	94	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	95	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	96	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	97	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	98	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	99	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	100	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	101	AC LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	102	16A 4 WAY ADAPTOR	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	103	16A 4 WAY ADAPTOR	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	104	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	105	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	106	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	107	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	108	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	109	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	110	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	111	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	112	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	113	EXT LEAD	30/11/2022	Pass	0.05 Ω	> 99.9 MΩ	Normal Pass
ABC INFLATABLES	CT93DT	114	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	115	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass
ABC INFLATABLES	CT93DT	116	16A LEAD	30/11/2022	Pass		> 99.9 MΩ	Pass

ABC INFLATABLES	CT93DT	156	AC LEAD	30/11/2022	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	157	SMOKE MC	30/11/2022	Pass		15.98 MΩ	< 0.10 mA	4VA	Pass
ABC INFLATABLES	CT93DT	158	DISCO CUBE PSU	30/11/2022	Pass		> 99.9 MΩ		4VA	Pass
ABC INFLATABLES	CT93DT	159	DISCO CUBE PSU	30/11/2022	Pass		> 99.9 MΩ		4VA	Pass
ABC INFLATABLES	CT93DT	160	DISCO CUBE PSU	30/11/2022	Pass		> 99.9 MΩ		4VA	Pass
ABC INFLATABLES	CT93DT	161	DISCO CUBE PSU	30/11/2022	Pass		> 99.9 MΩ		4VA	Pass
ABC INFLATABLES	CT93DT	162	EXT LEAD	30/11/2022	Pass	0.11 Ω	> 99.9 MΩ			Normal
ABC INFLATABLES	CT93DT	163	SPEAKER PSU	30/11/2022	Pass		> 99.9 MΩ		6VA	Pass
ABC INFLATABLES	CT93DT	164	LIGHT PSU	30/11/2022	Pass		> 99.9 MΩ		4VA	Pass
ABC INFLATABLES	CT93DT	165	SEWING MC	30/11/2022	Pass		46.06 MΩ	< 0.10 mA	4VA	Pass
ABC INFLATABLES	CT93DT	166	FRIDGE	30/11/2022	Pass	< 0.01 Ω	82.14 MΩ	< 0.10 mA	91VA	Pass
ABC INFLATABLES	CT93DT	167	CANDYFLOSS MC	30/11/2022	Pass	< 0.01 Ω	85.35 MΩ	< 0.10 mA	88VA	Pass
ABC INFLATABLES	CT93DT	168	CANDYFLOSS MC	30/11/2022	Pass	< 0.01 Ω	> 99.9 MΩ	< 0.10 mA	109VA	Pass
ABC INFLATABLES	CT93DT	169	AC LEAD	30/11/2022	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	170	AC LEAD	30/11/2022	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	171	AC LEAD	30/11/2022	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	172	SMOKE MC	30/11/2022	Pass		> 99.9 MΩ	< 0.10 mA	404VA	Pass
ABC INFLATABLES	CT93DT	173	PSU	30/11/2022	Pass		> 99.9 MΩ		16VA	Pass
ABC INFLATABLES	CT93DT	174	EXT LEAD	30/11/2022	Pass	0.17 Ω	> 99.9 MΩ			Normal
ABC INFLATABLES	CT93DT	175	CCTV	30/11/2022	Pass		> 99.9 MΩ		26VA	Pass
ABC INFLATABLES	CT93DT	176	CAMERAS	30/11/2022	Pass		> 99.9 MΩ		4VA	Pass
ABC INFLATABLES	CT93DT	177	CAMERAS	30/11/2022	Pass		> 99.9 MΩ		4VA	Pass
ABC INFLATABLES	CT93DT	178	BATTERY CHARGER	30/11/2022	Pass		> 99.9 MΩ		6VA	Pass
ABC INFLATABLES	CT93DT	179	EXT LEAD	30/11/2022	Pass	0.18 Ω	> 99.9 MΩ			Normal
ABC INFLATABLES	CT93DT	180	EXT LEAD	30/11/2022	Pass	0.33 Ω	> 99.9 MΩ			Normal
ABC INFLATABLES	CT93DT	181	ROUTER	30/11/2022	Pass		> 99.9 MΩ		4VA	Pass
ABC INFLATABLES	CT93DT	182	PSU	30/11/2022	Pass		> 99.9 MΩ		4VA	Pass
ABC INFLATABLES	CT93DT	183	PRINTER	30/11/2022	Pass		> 99.9 MΩ		8VA	Pass
ABC INFLATABLES	CT93DT	184	AC LEAD	30/11/2022	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	185	ADAPTOR	30/11/2022	Pass	0.03 Ω	> 99.9 MΩ			Normal
ABC INFLATABLES	CT93DT	186	PSU	30/11/2022	Pass		> 99.9 MΩ		4VA	Pass
ABC INFLATABLES	CT93DT	187	EXT LEAD	30/11/2022	Pass	0.06 Ω	> 99.9 MΩ			Normal
ABC INFLATABLES	CT93DT	188	EXT LEAD	30/11/2022	Pass	0.13 Ω	> 99.9 MΩ			Normal
ABC INFLATABLES	CT93DT	189	BLOWER	30/11/2022	Pass		> 99.9 MΩ		2353VA	Pass
ABC INFLATABLES	CT93DT	190	AC LEAD	30/11/2022	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	191	PROJECTOR	30/11/2022	Pass		> 99.9 MΩ		7VA	Pass
ABC INFLATABLES	CT93DT	192	RF RECIVER PSU	30/11/2022	Pass		> 99.9 MΩ		4VA	Pass
ABC INFLATABLES	CT93DT	193	RF RECIVER PSU	30/11/2022	Pass		> 99.9 MΩ		4VA	Pass
ABC INFLATABLES	CT93DT	194	LAPTOP CHARGER	30/11/2022	Pass		> 99.9 MΩ		7VA	Pass

ABC INFLATABLES	CT93DT	195	AC LEAD	30/11/2022	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	196	AC LEAD	30/11/2022	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	197	AC LEAD	30/11/2022	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	198	AC LEAD	30/11/2022	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	199	AC LEAD	30/11/2022	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	200	AC LEAD	30/11/2022	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	201	16A LEAD	30/11/2022	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	202	LED LIGHTPSU	30/11/2022	Pass		> 99.9 MΩ	10VA		Pass
ABC INFLATABLES	CT93DT	203	LED LIGHT PSU	30/11/2022	Pass		> 99.9 MΩ	4VA		Pass
ABC INFLATABLES	CT93DT	204	TRIP SWITCH	30/11/2022	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	205	EXT LEAD	30/11/2022	Pass	0.15 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	206	EXT LEAD	30/11/2022	Pass	0.1 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	207	EXT LEAD	30/11/2022	Pass	0.17 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	208	EXT LEAD	30/11/2022	Pass	0.24 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	209	SPEAKER	30/11/2022	Pass		1.0 MΩ	0.50 mA	36VA	Pass
ABC INFLATABLES	CT93DT	210	SPEAKER	30/11/2022	Pass		1.08 MΩ	0.49 mA	32VA	Pass
ABC INFLATABLES	CT93DT	211	LIGHT	30/11/2022	Pass		> 99.9 MΩ		16VA	Pass
ABC INFLATABLES	CT93DT	212	LIGHT	30/11/2022	Pass		> 99.9 MΩ		12VA	Pass
ABC INFLATABLES	CT93DT	213	BLOWER	30/11/2022	Pass		13.64 MΩ	0.20 mA	2296VA	Pass
ABC INFLATABLES	CT93DT	214	BLOWER	30/11/2022	Pass		5.93 MΩ	0.16 mA	2319VA	Pass
ABC INFLATABLES	CT93DT	215	BLOWER	30/11/2022	Pass		> 99.9 MΩ	< 0.10 mA	473VA	Pass
ABC INFLATABLES	CT93DT	216	BLOWER	30/11/2022	Pass		1.36 MΩ	1.11 mA	2050VA	Pass
ABC INFLATABLES	CT93DT	217	BLOWER	30/11/2022	Pass		2.48 MΩ	1.88 mA	1041VA	Pass
ABC INFLATABLES	CT93DT	218	BLOWER	30/11/2022	Pass		22.91 MΩ	0.18 mA	1241VA	Pass
ABC INFLATABLES	CT93DT	219	BLOWER	30/11/2022	Pass		14.82 MΩ	0.22 mA	1861VA	Pass
ABC INFLATABLES	CT93DT	220	EXT LEAD	30/11/2022	Pass	0.23 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	221	EXT LEAD	30/11/2022	Pass	0.17 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	222	EXT LEAD	30/11/2022	Pass	0.17 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	223	EXT LEAD	30/11/2022	Pass	0.1 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	224	EXT LEAD	30/11/2022	Pass	0.11 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	225	EXT LEAD	30/11/2022	Pass	0.1 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	226	EXT LEAD	30/11/2022	Pass	0.32 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	227	PSU	30/11/2022	Pass		> 99.9 MΩ		4VA	Pass
ABC INFLATABLES	CT93DT	228	EXT LEAD	30/11/2022	Pass	0.08 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	229	EXT LEAD	30/11/2022	Pass	0.07 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	230	EXT LEAD	30/11/2022	Pass	0.33 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	231	EXT LEAD	30/11/2022	Pass	0.34 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	232	EXT LEAD	30/11/2022	Pass	0.33 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	233	EXT LEAD	30/11/2022	Pass	0.32 Ω	> 99.9 MΩ		Normal	Pass

ABC INFLATABLES	CT93DT	234	EXT LEAD	30/11/2022	Pass	0.33 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	235	EXT LEAD	30/11/2022	Pass	0.48 Ω	69.52 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	236	EXT LEAD	30/11/2022	Pass	0.31 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	237	BLOWER	30/11/2022	Pass		2.95 MΩ	0.28 mA	895VA		Pass
ABC INFLATABLES	CT93DT	238	BLOWER	30/11/2022	Pass		1.75 MΩ	1.13 mA	1041VA		Pass
ABC INFLATABLES	CT93DT	239	BLOWER	30/11/2022	Pass		15.94 MΩ	0.14 mA	2239VA		Pass
ABC INFLATABLES	CT93DT	240	BLOWER	30/11/2022	Pass		5.98 MΩ	1.23 mA	1859VA		Pass
ABC INFLATABLES	CT93DT	241	BLOWER	30/11/2022	Pass		3.42 MΩ	0.57 mA	1865VA		Pass
ABC INFLATABLES	CT93DT	242	BLOWER	30/11/2022	Pass		59.27 MΩ	0.75 mA	1544VA		Pass
ABC INFLATABLES	CT93DT	243	BLOWER	30/11/2022	Pass		1.46 MΩ	1.20 mA	1229VA		Pass
ABC INFLATABLES	CT93DT	244	16A LEAD	30/11/2022	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT93DT	245	BLOWER	30/11/2022	Fail						Fail
ABC INFLATABLES	CT93DT	246	BLOWER	30/11/2022	Fail						Fail
ABC INFLATABLES	CT93DT	247	BLOWER	30/11/2022	Fail						Fail
ABC INFLATABLES	CT93DT	248	BLOWER	30/11/2022	Fail						Fail
ABC INFLATABLES	CT93DT	249	POPCORN MC	30/11/2022	Fail						Fail
ABC INFLATABLES	CT93DT	250	EXT LEAD	30/11/2022	Fail						Fail
ABC INFLATABLES	CT93DT	251	16A LEAD	30/11/2022	Fail						Fail
ABC INFLATABLES	CT93DT	252	16A LEAD	30/11/2022	Fail						Fail
ABC INFLATABLES	CT93DT	253	16A LEAD	30/11/2022	Fail						Fail
ABC INFLATABLES	CT93DT	254	16A LEAD	30/11/2022	Fail						Fail
ABC INFLATABLES	CT93DT	255	16A LEAD	30/11/2022	Fail						Fail
ABC INFLATABLES	CT93DT	256	16A LEAD	30/11/2022	Fail						Fail
ABC INFLATABLES	CT93DT	257	PSU	30/11/2022	Fail						Fail