

Client	Location	ID	Description	Test Date	Visual	Continuity	Insulation	Leakage	VA	Polarity	Test Overall Status
ABC INFLATABLES	CT9 3DT	1	BLOWER	07/11/2018	Pass		39.66 MΩ	0.15 mA	987VA		Pass
ABC INFLATABLES	CT9 3DT	2	BLOWER	07/11/2018	Pass		26.59 MΩ	0.18 mA	973VA		Pass
ABC INFLATABLES	CT9 3DT	3	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.15 mA	694VA		Pass
ABC INFLATABLES	CT9 3DT	4	BLOWER	07/11/2018	Pass		72.91 MΩ	0.16 mA	946VA		Pass
ABC INFLATABLES	CT9 3DT	5	BLOWER	07/11/2018	Pass		18.18 MΩ	0.21 mA	955VA		Pass
ABC INFLATABLES	CT9 3DT	6	BLOWER	07/11/2018	Pass		63.41 MΩ	0.14 mA	985VA		Pass
ABC INFLATABLES	CT9 3DT	7	BLOWER	07/11/2018	Pass		31.24 MΩ	0.19 mA	996VA		Pass
ABC INFLATABLES	CT9 3DT	8	BLOWER	07/11/2018	Pass		13.33 MΩ	0.17 mA	969VA		Pass
ABC INFLATABLES	CT9 3DT	9	BLOWER	07/11/2018	Pass		35.68 MΩ	0.21 mA	956VA		Pass
ABC INFLATABLES	CT9 3DT	10	BLOWER	07/11/2018	Pass		18.39 MΩ	0.42 mA	1859VA		Pass
ABC INFLATABLES	CT9 3DT	11	BLOWER	07/11/2018	Pass		10.52 MΩ	0.48 mA	1844VA		Pass
ABC INFLATABLES	CT9 3DT	12	BLOWER	07/11/2018	Pass		35.94 MΩ	0.27 mA	1866VA		Pass
ABC INFLATABLES	CT9 3DT	13	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.18 mA	1811VA		Pass
ABC INFLATABLES	CT9 3DT	14	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.20 mA	1820VA		Pass
ABC INFLATABLES	CT9 3DT	15	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.15 mA	1499VA		Pass
ABC INFLATABLES	CT9 3DT	16	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.15 mA	1690VA		Pass
ABC INFLATABLES	CT9 3DT	17	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.16 mA	1449VA		Pass
ABC INFLATABLES	CT9 3DT	18	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.14 mA	1512VA		Pass
ABC INFLATABLES	CT9 3DT	19	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.15 mA	1420VA		Pass
ABC INFLATABLES	CT9 3DT	20	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.13 mA	1209VA		Pass
ABC INFLATABLES	CT9 3DT	21	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.16 mA	1440VA		Pass
ABC INFLATABLES	CT9 3DT	22	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.14 mA	1327VA		Pass
ABC INFLATABLES	CT9 3DT	23	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.15 mA	1361VA		Pass
ABC INFLATABLES	CT9 3DT	24	BLOWER	07/11/2018	Fail						Fail
ABC INFLATABLES	CT9 3DT	25	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.15 mA	1433VA		Pass
ABC INFLATABLES	CT9 3DT	26	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.15 mA	2351VA		Pass
ABC INFLATABLES	CT9 3DT	27	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.15 mA	1653VA		Pass
ABC INFLATABLES	CT9 3DT	28	BLOWER	07/11/2018	Fail						Fail
ABC INFLATABLES	CT9 3DT	29	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.13 mA	1763VA		Pass
ABC INFLATABLES	CT9 3DT	30	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.16 mA	1808VA		Pass
ABC INFLATABLES	CT9 3DT	31	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.16 mA	1863VA		Pass
ABC INFLATABLES	CT9 3DT	32	BLOWER	07/11/2018	Fail						Fail
ABC INFLATABLES	CT9 3DT	33	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.13 mA	1012VA		Pass
ABC INFLATABLES	CT9 3DT	34	BLOWER	07/11/2018	Fail						Fail
ABC INFLATABLES	CT9 3DT	35	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.14 mA	1327VA		Pass
ABC INFLATABLES	CT9 3DT	36	BLOWER	07/11/2018	Fail						Fail
ABC INFLATABLES	CT9 3DT	37	BLOWER	07/11/2018	Fail						Fail
ABC INFLATABLES	CT9 3DT	38	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.12 mA	1738VA		Pass

ABC INFLATABLES	CT9 3DT	39	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.11 mA	1597VA	Pass
ABC INFLATABLES	CT9 3DT	40	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.11 mA	1464VA	Pass
ABC INFLATABLES	CT9 3DT	41	BLOWER	07/11/2018	Pass		> 99.9 MΩ	< 0.10 mA	1481VA	Pass
ABC INFLATABLES	CT9 3DT	42	BLOWER	07/11/2018	Fail					Fail
ABC INFLATABLES	CT9 3DT	43	BLOWER	07/11/2018	Pass		> 99.9 MΩ	< 0.10 mA	1570VA	Pass
ABC INFLATABLES	CT9 3DT	44	BLOWER	07/11/2018	Pass					Pass
ABC INFLATABLES	CT9 3DT	45	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	46	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	47	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	48	16A LEAD	07/11/2018	Fail					Fail
ABC INFLATABLES	CT9 3DT	49	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	50	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	51	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	52	16A LEAD	07/11/2018	Fail					Fail
ABC INFLATABLES	CT9 3DT	53	16A LEAD	07/11/2018	Fail					Fail
ABC INFLATABLES	CT9 3DT	54	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	55	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	56	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	57	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	58	HEATER	07/11/2018	Pass		> 99.9 MΩ	0.12 mA	2204VA	Pass
ABC INFLATABLES	CT9 3DT	59	BLOWER	07/11/2018	Pass		> 99.9 MΩ	< 0.10 mA	1465VA	Pass
ABC INFLATABLES	CT9 3DT	60	PSU	07/11/2018	Pass		> 99.9 MΩ		OVA	Pass
ABC INFLATABLES	CT9 3DT	61	PSU	07/11/2018	Pass		> 99.9 MΩ		OVA	Pass
ABC INFLATABLES	CT9 3DT	62	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	63	16A LEAD	07/11/2018	Fail					Fail
ABC INFLATABLES	CT9 3DT	64	EXT LEAD	07/11/2018	Pass	0.41 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	65	EXT LEAD	07/11/2018	Pass	0.42 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	66	EXT LEAD	07/11/2018	Pass	0.78 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	67	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	68	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	69	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	70	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	71	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	72	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	73	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	74	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	75	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	76	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	77	EXT LEAD	07/11/2018	Pass	0.13 Ω	> 99.9 MΩ		Normal	Pass

ABC INFLATABLES	CT9 3DT	78	EXT LEAD	07/11/2018	Pass	0.03 Ω	> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	79	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	80	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	81	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	82	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	83	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	84	16A LEAD	07/11/2018	Fail				Fail
ABC INFLATABLES	CT9 3DT	85	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	86	16A LEAD	07/11/2018	Fail				Fail
ABC INFLATABLES	CT9 3DT	87	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	88	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	89	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	90	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	91	16A LEAD	07/11/2018	Fail				Fail
ABC INFLATABLES	CT9 3DT	92	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	93	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	94	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	95	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	96	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	97	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	98	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	99	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	100	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	101	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	102	16A LEAD	07/11/2018	Fail				Fail
ABC INFLATABLES	CT9 3DT	103	16A ADAPTOR	07/11/2018	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT9 3DT	104	16A ADAPTOR	07/11/2018	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT9 3DT	105	16A ADAPTOR	07/11/2018	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT9 3DT	106	16A ADAPTOR	07/11/2018	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT9 3DT	107	16A ADAPTOR	07/11/2018	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT9 3DT	108	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	109	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	110	32A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	111	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	112	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	113	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	114	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	115	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT9 3DT	116	16A LEAD	07/11/2018	Pass		> 99.9 MΩ	Normal	Pass

ABC INFLATABLES	CT9 3DT	117	16A LEAD	07/11/2018	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	118	16A LEAD	07/11/2018	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	119	16A LEAD	07/11/2018	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	120	16A LEAD	07/11/2018	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	121	16A LEAD	07/11/2018	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	122	16A LEAD	07/11/2018	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	123	16A LEAD	07/11/2018	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	124	EXT LEAD	07/11/2018	Pass	0.21 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	125	EXT LEAD	07/11/2018	Pass	0.03 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	126	16A ADAPTOR	07/11/2018	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT9 3DT	127	AC LEAD	07/11/2018	Pass	0.42 Ω				Normal	Fail
ABC INFLATABLES	CT9 3DT	128	AC LEAD	07/11/2018	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT9 3DT	129	32A LEAD	07/11/2018	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT9 3DT	130	FLOSS MC	07/11/2018	Pass	0.05 Ω	64.71 MΩ	< 0.10 mA	1172VA		Pass
ABC INFLATABLES	CT9 3DT	131	EXT LEAD	07/11/2018	Pass	0.41 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	132	POPCORN MC	07/11/2018	Pass	0.06 Ω	2.3 MΩ	0.12 mA	1155VA		Pass
ABC INFLATABLES	CT9 3DT	133	BLOCK ROCKER	07/11/2018	Pass		> 99.9 MΩ		21VA		Pass
ABC INFLATABLES	CT9 3DT	134	BLOCK ROCKER	07/11/2018	Pass		> 99.9 MΩ		22VA		Pass
ABC INFLATABLES	CT9 3DT	135	LIGHT	07/11/2018	Pass		> 99.9 MΩ		0VA		Pass
ABC INFLATABLES	CT9 3DT	136	AC LEAD	07/11/2018	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT9 3DT	137	AC LEAD	07/11/2018	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT9 3DT	138	LIGHT	07/11/2018	Pass		> 99.9 MΩ		25VA		Pass
ABC INFLATABLES	CT9 3DT	139	BATTERY CHARGER	07/11/2018	Pass		> 99.9 MΩ		31VA		Pass
ABC INFLATABLES	CT9 3DT	140	BATTERY CHARGER	07/11/2018	Fail						Fail
ABC INFLATABLES	CT9 3DT	141	PSU	07/11/2018	Pass		> 99.9 MΩ		0VA		Pass
ABC INFLATABLES	CT9 3DT	142	JETWASH	07/11/2018	Pass		> 99.9 MΩ	< 0.10 mA	955VA		Pass
ABC INFLATABLES	CT9 3DT	143	LIGHT	07/11/2018	Pass		> 99.9 MΩ		5VA		Pass
ABC INFLATABLES	CT9 3DT	144	LIGHT	07/11/2018	Pass		> 99.9 MΩ		6VA		Pass
ABC INFLATABLES	CT9 3DT	145	PSU	07/11/2018	Pass		> 99.9 MΩ		0VA		Pass
ABC INFLATABLES	CT9 3DT	146	CCTV	07/11/2018	Pass		> 99.9 MΩ		14VA		Pass
ABC INFLATABLES	CT9 3DT	147	CAMERAS	07/11/2018	Pass		> 99.9 MΩ		5VA		Pass
ABC INFLATABLES	CT9 3DT	148	EXT LEAD	07/11/2018	Pass	0.03 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	149	EXT LEAD	07/11/2018	Pass	0.03 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	150	EXT LEAD	07/11/2018	Pass	0.03 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	151	PSU	07/11/2018	Pass		> 99.9 MΩ		0VA		Pass
ABC INFLATABLES	CT9 3DT	152	PRINTER	07/11/2018	Pass		> 99.9 MΩ		11VA		Pass
ABC INFLATABLES	CT9 3DT	153	AC LEAD	07/11/2018	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT9 3DT	154	AC LEAD	07/11/2018	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT9 3DT	155	MONITOR	07/11/2018	Pass		> 99.9 MΩ		10VA		Pass

ABC INFLATABLES	CT9 3DT	156	CHARGER	07/11/2018	Pass		> 99.9 MΩ		OVA	Pass
ABC INFLATABLES	CT9 3DT	157	FAN	07/11/2018	Pass		> 99.9 MΩ		29VA	Pass
ABC INFLATABLES	CT9 3DT	158	EXT LEAD	07/11/2018	Pass	0.03 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	159	16A LEAD	07/11/2018	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	160	SMOKE MC	07/11/2018	Pass		> 99.9 MΩ		364VA	Pass
ABC INFLATABLES	CT9 3DT	161	LAPTOP CHARGER	07/11/2018	Pass		> 99.9 MΩ		OVA	Pass
ABC INFLATABLES	CT9 3DT	162	AC LEAD	07/11/2018	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	163	LIGHT	07/11/2018	Pass		> 99.9 MΩ		25VA	Pass
ABC INFLATABLES	CT9 3DT	164	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	165	16A LEAD	07/11/2018	Fail					Fail
ABC INFLATABLES	CT9 3DT	166	PSU	07/11/2018	Pass		> 99.9 MΩ		OVA	Pass
ABC INFLATABLES	CT9 3DT	167	16A LEAD	07/11/2018	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	168	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.12 mA	714VA	Pass
ABC INFLATABLES	CT9 3DT	169	LIGHT	07/11/2018	Pass		> 99.9 MΩ		70VA	Pass
ABC INFLATABLES	CT9 3DT	170	LIGHT	07/11/2018	Pass		> 99.9 MΩ		20VA	Pass
ABC INFLATABLES	CT9 3DT	171	16A LEAD	07/11/2018	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	172	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.13 mA	1003VA	Pass
ABC INFLATABLES	CT9 3DT	173	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.17 mA	1328VA	Pass
ABC INFLATABLES	CT9 3DT	174	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.11 mA	724VA	Pass
ABC INFLATABLES	CT9 3DT	176	BLOWER	07/11/2018	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	177	SPEAKER	07/11/2018	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	178	SPEAKER	07/11/2018	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	179	EXT LEAD	07/11/2018	Pass	0.79 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	180	AMP	07/11/2018	Pass		> 99.9 MΩ		OVA	Pass
ABC INFLATABLES	CT9 3DT	181	CHARGER	07/11/2018	Pass		> 99.9 MΩ		3VA	Pass
ABC INFLATABLES	CT9 3DT	182	CHARGER	07/11/2018	Pass		> 99.9 MΩ		OVA	Pass
ABC INFLATABLES	CT9 3DT	183	CHARGER	07/11/2018	Fail					Fail
ABC INFLATABLES	CT9 3DT	184	CHARGER	07/11/2018	Pass		> 99.9 MΩ		OVA	Pass
ABC INFLATABLES	CT9 3DT	185	AC LEAD	07/11/2018	Pass	0.04 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	186	AC LEAD	07/11/2018	Pass	0.06 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	187	AC LEAD	07/11/2018	Pass	0.29 Ω			Normal	Fail
ABC INFLATABLES	CT9 3DT	188	AC LEAD	07/11/2018	Pass	0.09 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	189	AC LEAD	07/11/2018	Pass	0.07 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	190	AC LEAD	07/11/2018	Pass	0.06 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	191	AC LEAD	07/11/2018	Pass	0.19 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	192	AC LEAD	07/11/2018	Pass	0.08 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	193	TRIP SWITCH	07/11/2018	Pass		> 99.9 MΩ		OVA	Pass
ABC INFLATABLES	CT9 3DT	194	ADAPTOR	07/11/2018	Pass	0.04 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	195	ADAPTOR	07/11/2018	Pass	0.03 Ω	> 99.9 MΩ		Normal	Pass

ABC INFLATABLES	CT9 3DT	196	ADAPTOR	07/11/2018	Pass	0.09 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	197	EXT LEAD	07/11/2018	Pass	0.08 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	198	EXT LEAD	07/11/2018	Pass	0.06 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	199	EXT LEAD	07/11/2018	Pass	0.06 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	200	EXT LEAD	07/11/2018	Pass	0.34 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	201	EXT LEAD	07/11/2018	Pass	0.33 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	202	PSU	07/11/2018	Fail						Fail
ABC INFLATABLES	CT9 3DT	203	16A LEAD	07/11/2018	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT9 3DT	204	BLOWER	07/11/2018	Pass		> 99.9 MΩ	< 0.10 mA	1534VA		Pass
ABC INFLATABLES	CT9 3DT	205	BLOWER	07/11/2018	Pass		> 99.9 MΩ	0.15 mA	1415VA		Pass
ABC INFLATABLES	CT9 3DT	206	16A LEAD	07/11/2018	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	207	16A LEAD	07/11/2018	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	208	16A LEAD	07/11/2018	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	209	16A LEAD	07/11/2018	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	210	16A LEAD	07/11/2018	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	211	BLOWER	07/11/2018	Pass		28.62 MΩ	0.29 mA	1821VA		Pass
ABC INFLATABLES	CT9 3DT	212	BLOWER	07/11/2018	Pass		8.03 MΩ	0.49 mA	1933VA		Pass
ABC INFLATABLES	CT9 3DT	213	16A LEAD	07/11/2018	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	214	EXT LEAD	07/11/2018	Fail						Fail
ABC INFLATABLES	CT9 3DT	215	EXT LEAD	07/11/2018	Fail						Fail
ABC INFLATABLES	CT9 3DT	216	EXT LEAD	07/11/2018	Pass	0.34 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	217	EXT LEAD	07/11/2018	Pass	0.77 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	218	BATTERY CHARGER	07/11/2018	Pass		> 99.9 MΩ		9VA		Pass
ABC INFLATABLES	CT9 3DT	219	FLOOR CLEANER	07/11/2018	Pass		> 99.9 MΩ		0VA		Pass
ABC INFLATABLES	CT9 3DT	220	FLOOR CLEANER	07/11/2018	Pass		> 99.9 MΩ		55VA		Pass
ABC INFLATABLES	CT9 3DT	221	HOOVER	07/11/2018	Pass		> 99.9 MΩ		0VA		Pass
ABC INFLATABLES	CT9 3DT	222	HOOVER	07/11/2018	Pass		> 99.9 MΩ		875VA		Pass
ABC INFLATABLES	CT9 3DT	223	BLOWER	07/11/2018	Pass		> 99.9 MΩ		1379VA		Pass
ABC INFLATABLES	CT9 3DT	224	FLOOR CLEANER	07/11/2018	Pass		> 99.9 MΩ	< 0.10 mA	0VA		Pass
ABC INFLATABLES	CT9 3DT	225	EXT LEAD	07/11/2018	Pass	0.05 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	226	EXT LEAD	07/11/2018	Pass	0.14 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	227	EXT LEAD	07/11/2018	Pass	0.62 Ω				Normal	Fail
ABC INFLATABLES	CT9 3DT	228	PSU	07/11/2018	Pass		> 99.9 MΩ		4VA		Pass
ABC INFLATABLES	CT9 3DT	229	AC LEAD	07/11/2018	Pass	0.1 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	230	AC LEAD	07/11/2018	Pass	0.06 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	231	AC LEAD	07/11/2018	Pass	0.17 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	232	AC LEAD	07/11/2018	Pass	0.51 Ω				Normal	Fail
ABC INFLATABLES	CT9 3DT	233	AC LEAD	07/11/2018	Pass	0.07 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	234	AC LEAD	07/11/2018	Pass	0.06 Ω	> 99.9 MΩ			Normal	Pass

ABC INFLATABLES	CT9 3DT	235	AC LEAD	07/11/2018	Pass	0.1 $\Omega$	> 99.9 M $\Omega$		Normal	Pass
ABC INFLATABLES	CT9 3DT	236	AC LEAD	07/11/2018	Pass		> 99.9 M $\Omega$			Pass
ABC INFLATABLES	CT9 3DT	237	PSU	07/11/2018	Pass		> 99.9 M $\Omega$	6VA		Pass
ABC INFLATABLES	CT9 3DT	238	MINI FRIDGE	07/11/2018	Pass		> 99.9 M $\Omega$	3VA		Pass
ABC INFLATABLES	CT9 3DT	239	LNICAT WARMER	07/11/2018	Pass	0.21 $\Omega$	76.1 M $\Omega$	< 0.10 mA	0VA	Pass