

# PAT TEST SPECIALIST

## CERTIFICATE OF ELECTRICAL TESTING

This certifies that

ABC inflatable's, 20 Simon Avenue, Margate, Kent, CT9 3DT

Had their PAT testing done on

DATE OF TEST 07/11/19

The electrical appliances on these premises have been inspected and tested for electrical safety to the requirements of the electricity at work regulations

Retest date 07/11/20

Tested by Jason Cairns

PAT TEST SPECIALIST

Portable Appliance Testing

1 Quex View Road, Birchington

Kent, CT7 0DZ

Phone: **01843 842762** Mobile: **07725460276**

**[www.pattesting-kent.com](http://www.pattesting-kent.com)**

Client	Location	ID	Description	Test Date	Visual	Continuity	Insulation	Leakage	VA	Polarity	Test Overall Status
ABC INFLATABLES	CT9 3DT	1	EXT LEAD	07/11/2019	Pass	0.56 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	2	EXT LEAD	07/11/2019	Pass	0.61 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	3	EXT LEAD	07/11/2019	Pass	0.58 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	4	EXT LEAD	07/11/2019	Pass	0.92 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	5	EXT LEAD	07/11/2019	Pass	0.59 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	6	EXT LEAD	07/11/2019	Pass	0.61 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	7	EXT LEAD	07/11/2019	Pass	0.66 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	8	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	9	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	10	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	11	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	12	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	13	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	14	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	15	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	16	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	17	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	18	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	19	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	20	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	21	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	22	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	23	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	24	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	25	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	26	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	27	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	28	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	29	16A LEAD	07/11/2019	Fail						Fail
ABC INFLATABLES	CT9 3DT	30	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	31	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	32	32A EXT LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	33	32A EXT LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	34	32A EXT LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	35	32A EXT LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	36	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	37	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	38	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass



ABC INFLATABLES	CT9 3DT	78	EXT LEAD	07/11/2019	Pass	0.55 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	79	EXT LEAD	07/11/2019	Pass	0.45 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	80	EXT LEAD	07/11/2019	Pass	0.53 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	81	EXT LEAD	07/11/2019	Fail						Fail
ABC INFLATABLES	CT9 3DT	82	EXT LEAD	07/11/2019	Pass	0.95 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	83	EXT LEAD	07/11/2019	Pass	0.22 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	84	EXT LEAD	07/11/2019	Pass	0.58 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	85	EXT LEAD	07/11/2019	Pass	0.54 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	86	16A LEAD	07/11/2019	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT9 3DT	87	16A BLOWER	07/11/2019	Pass	< 0.01 Ω	> 99.9 MΩ	< 0.10 mA	1489VA		Pass
ABC INFLATABLES	CT9 3DT	88	BLOWER	07/11/2019	Pass		> 99.9 MΩ	< 0.10 mA	0VA		Pass
ABC INFLATABLES	CT9 3DT	89	BLOWER	07/11/2019	Fail						Fail
ABC INFLATABLES	CT9 3DT	90	HEATER	07/11/2019	Pass	< 0.01 Ω	15.38 MΩ	0.13 mA	1961VA		Pass
ABC INFLATABLES	CT9 3DT	91	BLOWER	07/11/2019	Pass		> 99.9 MΩ	0.11 mA	1653VA		Pass
ABC INFLATABLES	CT9 3DT	92	EXT LEAD	07/11/2019	Pass	0.37 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	93	ADAPTOR	07/11/2019	Pass	0.13 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	94	CHARGER	07/11/2019	Pass		> 99.9 MΩ		0VA		Pass
ABC INFLATABLES	CT9 3DT	95	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ	0.16 mA	1433VA		Pass
ABC INFLATABLES	CT9 3DT	96	16A BLOWER	07/11/2019	Pass	< 0.01 Ω	> 99.9 MΩ	0.15 mA	1312VA		Pass
ABC INFLATABLES	CT9 3DT	97	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ	0.14 mA	982VA		Pass
ABC INFLATABLES	CT9 3DT	98	16A BLOWER	07/11/2019	Pass	0.13 Ω	> 99.9 MΩ	0.16 mA	1442VA		Pass
ABC INFLATABLES	CT9 3DT	99	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ	0.16 mA	1390VA		Pass
ABC INFLATABLES	CT9 3DT	100	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	101	BLOWER	07/11/2019	Pass		32.07 MΩ	0.28 mA	1854VA		Pass
ABC INFLATABLES	CT9 3DT	102	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	103	16A BLOWER	07/11/2019	Pass	0.14 Ω	> 99.9 MΩ	0.15 mA	1307VA		Pass
ABC INFLATABLES	CT9 3DT	104	16A BLOWER	07/11/2019	Pass	0.05 Ω	> 99.9 MΩ	0.15 mA	1377VA		Pass
ABC INFLATABLES	CT9 3DT	105	16A BLOWER	07/11/2019	Pass	0.1 Ω	> 99.9 MΩ	0.15 mA	1423VA		Pass
ABC INFLATABLES	CT9 3DT	106	16A BLOWER	07/11/2019	Pass	0.05 Ω	> 99.9 MΩ	0.15 mA	1442VA		Pass
ABC INFLATABLES	CT9 3DT	107	16A BLOWER	07/11/2019	Pass	0.11 Ω	> 99.9 MΩ	0.15 mA	1307VA		Pass
ABC INFLATABLES	CT9 3DT	108	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	109	16A LEAD	07/11/2019	Pass	< 0.01 Ω	> 99.9 MΩ	0.14 mA	1283VA		Pass
ABC INFLATABLES	CT9 3DT	110	16A LEAD	07/11/2019	Pass		> 99.9 MΩ	< 0.10 mA	1451VA		Pass
ABC INFLATABLES	CT9 3DT	111	16A BLOWER	07/11/2019	Pass	< 0.01 Ω	> 99.9 MΩ	0.15 mA	1346VA		Pass
ABC INFLATABLES	CT9 3DT	112	16A BLOWER	07/11/2019	Pass	0.17 Ω	> 99.9 MΩ	0.16 mA	1516VA		Pass
ABC INFLATABLES	CT9 3DT	113	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ	0.15 mA	1391VA		Pass
ABC INFLATABLES	CT9 3DT	114	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ	< 0.10 mA	1350VA		Pass
ABC INFLATABLES	CT9 3DT	115	16A BLOWER	07/11/2019	Pass		99.51 MΩ	0.16 mA	1598VA		Pass
ABC INFLATABLES	CT9 3DT	116	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ	0.15 mA	1397VA		Pass

ABC INFLATABLES	CT9 3DT	117	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ	< 0.10 mA	1528VA	Pass	
ABC INFLATABLES	CT9 3DT	118	16A BLOWER	07/11/2019	Pass	0.04 Ω	> 99.9 MΩ	0.15 mA	1500VA	Pass	
ABC INFLATABLES	CT9 3DT	119	16A BLOWER	07/11/2019	Pass	< 0.01 Ω	> 99.9 MΩ	0.14 mA	1516VA	Pass	
ABC INFLATABLES	CT9 3DT	120	16A BLOWER	07/11/2019	Pass	< 0.01 Ω	> 99.9 MΩ	0.15 mA	1359VA	Pass	
ABC INFLATABLES	CT9 3DT	121	16A BLOWER	07/11/2019	Pass	< 0.01 Ω	> 99.9 MΩ	0.16 mA	1416VA	Pass	
ABC INFLATABLES	CT9 3DT	122	16A BLOWER	07/11/2019	Pass	0.08 Ω	> 99.9 MΩ	0.15 mA	1488VA	Pass	
ABC INFLATABLES	CT9 3DT	123	BATTERY CHARGER	07/11/2019	Pass		> 99.9 MΩ		0VA	Pass	
ABC INFLATABLES	CT9 3DT	124	BATTERY CHARGER	07/11/2019	Pass		> 99.9 MΩ		36VA	Pass	
ABC INFLATABLES	CT9 3DT	125	BLOWER	07/11/2019	Pass		> 99.9 MΩ		2649VA	Pass	
ABC INFLATABLES	CT9 3DT	126	BLOWER	07/11/2019	Pass		> 99.9 MΩ		2805VA	Pass	
ABC INFLATABLES	CT9 3DT	127	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ		2528VA	Pass	
ABC INFLATABLES	CT9 3DT	128	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ		2623VA	Pass	
ABC INFLATABLES	CT9 3DT	129	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ		2116VA	Pass	
ABC INFLATABLES	CT9 3DT	130	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ		1643VA	Pass	
ABC INFLATABLES	CT9 3DT	131	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	132	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	133	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ		1691VA	Pass	
ABC INFLATABLES	CT9 3DT	134	BLOWER	07/11/2019	Pass		> 99.9 MΩ		2270VA	Pass	
ABC INFLATABLES	CT9 3DT	135	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ		2483VA	Pass	
ABC INFLATABLES	CT9 3DT	136	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ		2284VA	Pass	
ABC INFLATABLES	CT9 3DT	137	BLOWER	07/11/2019	Pass		> 99.9 MΩ		2426VA	Pass	
ABC INFLATABLES	CT9 3DT	138	BLOWER	07/11/2019	Pass		> 99.9 MΩ		2382VA	Pass	
ABC INFLATABLES	CT9 3DT	139	BLOWER	07/11/2019	Pass		> 99.9 MΩ		2203VA	Pass	
ABC INFLATABLES	CT9 3DT	140	BLOWER	07/11/2019	Pass		> 99.9 MΩ		2244VA	Pass	
ABC INFLATABLES	CT9 3DT	141	BLOWER	07/11/2019	Pass		> 99.9 MΩ		2235VA	Pass	
ABC INFLATABLES	CT9 3DT	142	BLOWER	07/11/2019	Pass		> 99.9 MΩ		2083VA	Pass	
ABC INFLATABLES	CT9 3DT	143	BLOWER	07/11/2019	Pass		> 99.9 MΩ		2099VA	Pass	
ABC INFLATABLES	CT9 3DT	144	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ		2187VA	Pass	
ABC INFLATABLES	CT9 3DT	145	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ		1615VA	Pass	
ABC INFLATABLES	CT9 3DT	146	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ		1714VA	Pass	
ABC INFLATABLES	CT9 3DT	147	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ		1647VA	Pass	
ABC INFLATABLES	CT9 3DT	148	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ		1818VA	Pass	
ABC INFLATABLES	CT9 3DT	149	BLOWER	07/11/2019	Pass		> 99.9 MΩ		1698VA	Pass	
ABC INFLATABLES	CT9 3DT	150	BLOWER	07/11/2019	Pass		> 99.9 MΩ	< 0.10 mA	209VA	Pass	
ABC INFLATABLES	CT9 3DT	151	LIGHT	07/11/2019	Pass		> 99.9 MΩ		193VA	Pass	
ABC INFLATABLES	CT9 3DT	152	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	153	32A EXT LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT9 3DT	154	POPCORN MC	07/11/2019	Pass		> 99.9 MΩ		384VA	Pass	
ABC INFLATABLES	CT9 3DT	155	16A LEAD	07/11/2019	Pass		> 99.9 MΩ			Normal	Pass

ABC INFLATABLES	CT9 3DT	156	16A LEAD	07/11/2019	Pass	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	157	16A LEAD	07/11/2019	Pass	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	158	16A LEAD	07/11/2019	Pass	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	159	16A LEAD	07/11/2019	Pass	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	160	16A LEAD	07/11/2019	Pass	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	161	16A LEAD	07/11/2019	Pass	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	162	16A LEAD	07/11/2019	Pass	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	163	16A LEAD	07/11/2019	Pass	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	164	16A LEAD	07/11/2019	Pass	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	165	16A LEAD	07/11/2019	Pass	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	166	BLOWER	07/11/2019	Pass	> 99.9 MΩ	91VA		Pass
ABC INFLATABLES	CT9 3DT	167	PRINTER	07/11/2019	Pass	> 99.9 MΩ	0VA		Pass
ABC INFLATABLES	CT9 3DT	168	EXT LEAD	07/11/2019	Pass	0.23 Ω > 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	169	LIGHTS	07/11/2019	Pass	> 99.9 MΩ	0VA		Pass
ABC INFLATABLES	CT9 3DT	170	PSU	07/11/2019	Pass	> 99.9 MΩ	25VA		Pass
ABC INFLATABLES	CT9 3DT	171	PSU	07/11/2019	Pass	> 99.9 MΩ	0VA		Pass
ABC INFLATABLES	CT9 3DT	172	16A ADAPTOR	07/11/2019	Pass	> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	173	POPCORN MC	07/11/2019	Pass	> 99.9 MΩ	3VA		Pass
ABC INFLATABLES	CT9 3DT	174	16A LEAD	07/11/2019	Pass	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	175	16A LEAD	07/11/2019	Pass	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	176	16A LEAD	07/11/2019	Pass	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	177	16A LEAD	07/11/2019	Pass	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	178	PSU	07/11/2019	Pass	> 99.9 MΩ	0VA		Pass
ABC INFLATABLES	CT9 3DT	179	PSU	07/11/2019	Pass	> 99.9 MΩ	0VA		Pass
ABC INFLATABLES	CT9 3DT	180	GLUE GUN	07/11/2019	Pass	> 99.9 MΩ	79VA		Pass
ABC INFLATABLES	CT9 3DT	181	ROUTER	07/11/2019	Pass				Pass
ABC INFLATABLES	CT9 3DT	182	CCTV	07/11/2019	Pass				Pass
ABC INFLATABLES	CT9 3DT	183	CCTV	07/11/2019	Pass				Pass
ABC INFLATABLES	CT9 3DT	184	CCTV	07/11/2019	Pass				Pass
ABC INFLATABLES	CT9 3DT	185	CCTV EXT LEAD	07/11/2019	Pass				Pass
ABC INFLATABLES	CT9 3DT	186	MONITOR	07/11/2019	Pass	> 99.9 MΩ	3VA		Pass
ABC INFLATABLES	CT9 3DT	187	AC LEAD	07/11/2019	Pass	> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	188	FAN	07/11/2019	Fail				Fail
ABC INFLATABLES	CT9 3DT	189	PSU	07/11/2019	Pass	> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	190	PRINTER	07/11/2019	Pass	> 99.9 MΩ	8VA		Pass
ABC INFLATABLES	CT9 3DT	191	AC LEAD	07/11/2019	Pass	> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	192	CHARGER	07/11/2019	Pass	> 99.9 MΩ	0VA		Pass
ABC INFLATABLES	CT9 3DT	193	EXT LEAD	07/11/2019	Pass	0.14 Ω > 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	194	EXT LEAD	07/11/2019	Pass	0.4 Ω > 99.9 MΩ		Normal	Pass

ABC INFLATABLES	CT9 3DT	195	PSU	07/11/2019	Pass		> 99.9 MΩ		OVA	Pass
ABC INFLATABLES	CT9 3DT	196	LAMP	07/11/2019	Pass		> 99.9 MΩ		8VA	Pass
ABC INFLATABLES	CT9 3DT	197	SEWING MC	07/11/2019	Pass		> 99.9 MΩ		OVA	Pass
ABC INFLATABLES	CT9 3DT	198	ANGLE GRINDER	07/11/2019	Fail					Fail
ABC INFLATABLES	CT9 3DT	199	EXT LEAD	07/11/2019	Pass	0.19 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	200	EXT LEAD	07/11/2019	Pass	0.17 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	201	16A LEAD	07/11/2019	Fail					Fail
ABC INFLATABLES	CT9 3DT	202	FAN	07/11/2019	Pass		> 99.9 MΩ	0.12 mA	1377VA	Pass
ABC INFLATABLES	CT9 3DT	203	HOOVER	07/11/2019	Pass		> 99.9 MΩ		502VA	Pass
ABC INFLATABLES	CT9 3DT	204	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ		1847VA	Pass
ABC INFLATABLES	CT9 3DT	205	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ		1524VA	Pass
ABC INFLATABLES	CT9 3DT	206	16A LEAD	07/11/2019	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	207	16A LEAD	07/11/2019	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	208	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ		1615VA	Pass
ABC INFLATABLES	CT9 3DT	209	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ		1714VA	Pass
ABC INFLATABLES	CT9 3DT	210	16A BLOWER	07/11/2019	Pass		> 99.9 MΩ		1777VA	Pass
ABC INFLATABLES	CT9 3DT	211	16A LEAD	07/11/2019	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	212	16A LEAD	07/11/2019	Pass		> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	213	EXT LEAD	07/11/2019	Pass	0.47 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	214	EXT LEAD	07/11/2019	Pass	0.42 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	215	EXT LEAD	07/11/2019	Pass	0.84 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	216	EXT LEAD	07/11/2019	Pass	0.5 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	217	EXT LEAD	07/11/2019	Pass	0.22 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	218	EXT LEAD	07/11/2019	Pass	0.19 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	219	EXT LEAD	07/11/2019	Pass	0.26 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT9 3DT	220	LAPTOP CHARGER	07/11/2019	Pass		> 99.9 MΩ		6VA	Pass
ABC INFLATABLES	CT9 3DT	221	AC LEAD	07/11/2019	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	222	AC LEAD	07/11/2019	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	223	AC LEAD	07/11/2019	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	224	AC LEAD	07/11/2019	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	225	AC LEAD	07/11/2019	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	226	AC LEAD	07/11/2019	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	227	AC LEAD	07/11/2019	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	228	AC LEAD	07/11/2019	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	229	AC LEAD	07/11/2019	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	230	AC LEAD	07/11/2019	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	231	ADAPTOR	07/11/2019	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	232	ADAPTOR	07/11/2019	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT9 3DT	233	TRIPSWITCH	07/11/2019	Pass		> 99.9 MΩ			Pass

ABC INFLATABLES	CT9 3DT	234	EXT LEAD	07/11/2019	Pass	0.14 $\Omega$	> 99.9 M $\Omega$		Normal	Pass
ABC INFLATABLES	CT9 3DT	235	PSU	07/11/2019	Pass		> 99.9 M $\Omega$	3VA		Pass
ABC INFLATABLES	CT9 3DT	236	PSU	07/11/2019	Pass		> 99.9 M $\Omega$	0VA		Pass
ABC INFLATABLES	CT9 3DT	237	PSU	07/11/2019	Pass		> 99.9 M $\Omega$	0VA		Pass
ABC INFLATABLES	CT9 3DT	238	PSU	07/11/2019	Pass		> 99.9 M $\Omega$	3VA		Pass
ABC INFLATABLES	CT9 3DT	239	PSU	07/11/2019	Pass		> 99.9 M $\Omega$	0VA		Pass
ABC INFLATABLES	CT9 3DT	240	PSU	07/11/2019	Pass		> 99.9 M $\Omega$	0VA		Pass
ABC INFLATABLES	CT9 3DT	241	16A LEAD	07/11/2019	Pass		> 99.9 M $\Omega$		Normal	Pass
ABC INFLATABLES	CT9 3DT	242	SMOKE MC	07/11/2019	Pass		> 99.9 M $\Omega$	355VA		Pass
ABC INFLATABLES	CT9 3DT	243	LIGHT	07/11/2019	Pass		> 99.9 M $\Omega$			Pass
ABC INFLATABLES	CT9 3DT	244	LIGHT	07/11/2019	Pass		> 99.9 M $\Omega$			Pass
ABC INFLATABLES	CT9 3DT	245	SPEAKER	07/11/2019	Pass		> 99.9 M $\Omega$	0VA		Pass
ABC INFLATABLES	CT9 3DT	246	EXT LEAD	07/11/2019	Pass	0.09 $\Omega$	> 99.9 M $\Omega$		Normal	Pass
ABC INFLATABLES	CT9 3DT	247	TRIP SWITCJ	07/11/2019	Pass		> 99.9 M $\Omega$			Pass
ABC INFLATABLES	CT9 3DT	248	CARPET CLEANER	07/11/2019	Pass		> 99.9 M $\Omega$	< 0.10 mA	0VA	Pass
ABC INFLATABLES	CT9 3DT	249	CARPET CLEANER	07/11/2019	Pass		> 99.9 M $\Omega$		0VA	Pass
ABC INFLATABLES	CT9 3DT	250	COOL BOX	07/11/2019	Pass		> 99.9 M $\Omega$		3VA	Pass