

# PAT TEST SPECIALIST

## CERTIFICATE OF ELECTRICAL TESTING

This certifies that

ABC inflatable's, 20 Simon Avenue, Margate, Kent, CT9 3DT

Had their PAT testing done on

DATE OF TEST 30/11/21

The electrical appliances on these premises have been inspected and tested for electrical safety to the requirements of the electricity at work regulations

Retest date 30/11/22

Tested by Jason Cairns

PAT TEST SPECIALIST

Portable Appliance Testing

1 Quex View Road, Birchington

Kent, CT7 0DZ

Phone: **01843 842762** Mobile: **07725460276**

**[www.pattesting-kent.com](http://www.pattesting-kent.com)**

Client	Location	ID	Description	Test Date	Visual	Continuity	Insulation	Leakage	VA	Polarity	Test Overall Status
ABC INFLATABLES	CT93DT	1	EXT LEAD	30/11/2021	Pass	0.83 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	2	EXT LEAD	30/11/2021	Pass	0.37 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	3	EXT LEAD	30/11/2021	Pass	0.37 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	4	EXT LEAD	30/11/2021	Pass	0.48 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	5	EXT LEAD	30/11/2021	Pass	0.38 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	6	POP CORN MC	30/11/2021	Pass		> 99.9 MΩ		197VA		Pass
ABC INFLATABLES	CT93DT	7	POP CORN MC	30/11/2021	Pass		> 99.9 MΩ		1055VA		Pass
ABC INFLATABLES	CT93DT	8	FRIDGE	30/11/2021	Pass	< 0.01 Ω	56.41 MΩ	< 0.10 mA	89VA		Pass
ABC INFLATABLES	CT93DT	9	LIGHT	30/11/2021	Fail						Fail
ABC INFLATABLES	CT93DT	10	CANDYFLOSS MC	30/11/2021	Pass		6.69 MΩ	< 0.10 mA	1327VA		Pass
ABC INFLATABLES	CT93DT	11	CANDYFLOSS MC	30/11/2021	Pass		28.08 MΩ	< 0.10 mA	35VA		Pass
ABC INFLATABLES	CT93DT	12	CANDYFLOSS MC	30/11/2021	Pass		37.17 MΩ	< 0.10 mA	1114VA		Pass
ABC INFLATABLES	CT93DT	13	BLOWER	30/11/2021	Pass		> 99.9 MΩ		115VA		Pass
ABC INFLATABLES	CT93DT	14	BLOWER	30/11/2021	Pass		19.92 MΩ	0.60 mA	1571VA		Pass
ABC INFLATABLES	CT93DT	15	BLOWER	30/11/2021	Pass		54.49 MΩ	0.41 mA	2295VA		Pass
ABC INFLATABLES	CT93DT	16	BLOWER	30/11/2021	Pass		5.36 MΩ	0.74 mA	1934VA		Pass
ABC INFLATABLES	CT93DT	17	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.17 mA	1425VA		Pass
ABC INFLATABLES	CT93DT	18	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.16 mA	1311VA		Pass
ABC INFLATABLES	CT93DT	19	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.16 mA	1298VA		Pass
ABC INFLATABLES	CT93DT	20	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.15 mA	1243VA		Pass
ABC INFLATABLES	CT93DT	21	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.16 mA	1408VA		Pass
ABC INFLATABLES	CT93DT	22	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.15 mA	1264VA		Pass
ABC INFLATABLES	CT93DT	23	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.16 mA	1392VA		Pass
ABC INFLATABLES	CT93DT	24	BLOWER	30/11/2021	Pass		62.68 MΩ	0.17 mA	1545VA		Pass
ABC INFLATABLES	CT93DT	25	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.17 mA	1452VA		Pass
ABC INFLATABLES	CT93DT	26	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.16 mA	1389VA		Pass
ABC INFLATABLES	CT93DT	27	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.15 mA	1348VA		Pass
ABC INFLATABLES	CT93DT	28	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.16 mA	1321VA		Pass
ABC INFLATABLES	CT93DT	29	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.16 mA	1378VA		Pass
ABC INFLATABLES	CT93DT	30	BLOWER	30/11/2021	Fail						Fail
ABC INFLATABLES	CT93DT	31	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.16 mA	1276VA		Pass
ABC INFLATABLES	CT93DT	32	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.16 mA	1344VA		Pass
ABC INFLATABLES	CT93DT	33	16A LEAD	30/11/2021	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT93DT	34	16A LEAD	30/11/2021	Pass		> 99.9 MΩ				Pass
ABC INFLATABLES	CT93DT	35	BLOWER	30/11/2021	Pass		2.75 MΩ	0.60 mA	2582VA		Pass
ABC INFLATABLES	CT93DT	36	EXT LEAD	30/11/2021	Pass	0.36 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	37	EXT LEAD	30/11/2021	Pass	0.46 Ω	> 99.9 MΩ			Normal	Pass
ABC INFLATABLES	CT93DT	38	EXT LEAD	30/11/2021	Pass	0.36 Ω	> 99.9 MΩ			Normal	Pass

ABC INFLATABLES	CT93DT	39	EXT LEAD	30/11/2021	Pass	0.82 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	40	EXT LEAD	30/11/2021	Pass	0.79 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	41	EXT LEAD	30/11/2021	Pass	0.42 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	42	EXT LEAD	30/11/2021	Fail					Fail
ABC INFLATABLES	CT93DT	43	EXT LEAD	30/11/2021	Pass	0.11 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	44	EXT LEAD	30/11/2021	Pass	0.15 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	45	AC LEAD	30/11/2021	Pass	0.2 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	46	BUBBLE BLOWER	30/11/2021	Pass		> 99.9 MΩ	6VA		Pass
ABC INFLATABLES	CT93DT	47	EXT LEAD	30/11/2021	Pass	0.11 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	48	EXT LEAD	30/11/2021	Pass	0.39 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	49	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	50	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	51	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	52	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	53	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	54	16A ADAPTOR	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	55	16A ADAPTOR	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	56	16A ADAPTOR	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	57	16A ADAPTOR	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	58	16A ADAPTOR	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	59	16A ADAPTOR	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	60	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	61	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	62	HEATER	30/11/2021	Pass		7.65 MΩ	0.13 mA	1585VA	Pass
ABC INFLATABLES	CT93DT	63	BLOWER	30/11/2021	Pass		> 99.9 MΩ		1508VA	Pass
ABC INFLATABLES	CT93DT	64	BLOWER	30/11/2021	Pass		15.9 MΩ	0.78 mA	1722VA	Pass
ABC INFLATABLES	CT93DT	65	BLOWER	30/11/2021	Pass		28.45 MΩ	0.33 mA	1682VA	Pass
ABC INFLATABLES	CT93DT	66	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.15 mA	1110VA	Pass
ABC INFLATABLES	CT93DT	67	BLOWER	30/11/2021	Pass		39.52 MΩ	0.14 mA	1565VA	Pass
ABC INFLATABLES	CT93DT	68	BLOWER	30/11/2021	Pass		> 99.9 MΩ	< 0.10 mA	1536VA	Pass
ABC INFLATABLES	CT93DT	69	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.16 mA	1332VA	Pass
ABC INFLATABLES	CT93DT	70	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.16 mA	1446VA	Pass
ABC INFLATABLES	CT93DT	71	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.24 mA	2146VA	Pass
ABC INFLATABLES	CT93DT	72	BLOWER	30/11/2021	Pass		13.16 MΩ	0.63 mA	1701VA	Pass
ABC INFLATABLES	CT93DT	73	BLOWER	30/11/2021	Pass		5.93 MΩ	0.45 mA	1664VA	Pass
ABC INFLATABLES	CT93DT	74	BLOWER	30/11/2021	Pass		16.59 MΩ	0.34 mA	805VA	Pass
ABC INFLATABLES	CT93DT	75	BLOWER	30/11/2021	Pass		5.42 MΩ	0.25 mA	976VA	Pass
ABC INFLATABLES	CT93DT	76	BLOWER	30/11/2021	Pass		17.23 MΩ	0.16 mA	1015VA	Pass
ABC INFLATABLES	CT93DT	77	BLOWER	30/11/2021	Pass		2.76 MΩ	0.61 mA	1021VA	Pass

ABC INFLATABLES	CT93DT	78	BLOWER	30/11/2021	Pass		37.7 MΩ	0.18 mA	982VA	Pass
ABC INFLATABLES	CT93DT	79	BLOWER	30/11/2021	Pass		12.87 MΩ	0.23 mA	998VA	Pass
ABC INFLATABLES	CT93DT	80	BLOWER	30/11/2021	Pass		6.11 MΩ	0.38 mA	991VA	Pass
ABC INFLATABLES	CT93DT	81	BLOWER	30/11/2021	Pass		7.81 MΩ	0.42 mA	811VA	Pass
ABC INFLATABLES	CT93DT	82	BLOWER	30/11/2021	Pass		69.88 MΩ	0.23 mA	2253VA	Pass
ABC INFLATABLES	CT93DT	83	BLOWER	30/11/2021	Pass		2.16 MΩ	0.36 mA	1003VA	Pass
ABC INFLATABLES	CT93DT	84	BLOWER	30/11/2021	Fail					Fail
ABC INFLATABLES	CT93DT	85	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.17 mA	1362VA	Pass
ABC INFLATABLES	CT93DT	86	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.16 mA	1454VA	Pass
ABC INFLATABLES	CT93DT	87	BLOWER	30/11/2021	Pass		> 99.9 MΩ	< 0.10 mA	1395VA	Pass
ABC INFLATABLES	CT93DT	88	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	89	EXT LEAD	30/11/2021	Pass	0.11 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	90	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	91	LED LIGHT PU	30/11/2021	Pass		> 99.9 MΩ		9VA	Pass
ABC INFLATABLES	CT93DT	92	ADAPTOR	30/11/2021	Pass	0.16 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	93	ADAPTOR	30/11/2021	Pass	0.09 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	94	EXT LEAD	30/11/2021	Pass	0.12 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	95	TRIP SWITCH	30/11/2021	Pass		> 99.9 MΩ		OVA	Pass
ABC INFLATABLES	CT93DT	96	PSU	30/11/2021	Pass		> 99.9 MΩ		OVA	Pass
ABC INFLATABLES	CT93DT	97	PSU	30/11/2021	Pass		> 99.9 MΩ		OVA	Pass
ABC INFLATABLES	CT93DT	98	PSU	30/11/2021	Fail					Fail
ABC INFLATABLES	CT93DT	99	PSU	30/11/2021	Fail					Fail
ABC INFLATABLES	CT93DT	100	PSU	30/11/2021	Fail					Fail
ABC INFLATABLES	CT93DT	101	AC LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	102	AC LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	103	AC LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	104	AC LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	105	AC LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	106	AC LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	107	AC LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	108	AC LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	109	AC LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	110	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	111	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	112	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	113	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	114	16A ADAPTOR	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	115	16A ADAPTOR	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	116	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass

ABC INFLATABLES	CT93DT	117	PSU	30/11/2021	Pass		> 99.9 MΩ	OVA	Pass
ABC INFLATABLES	CT93DT	118	PSU	30/11/2021	Pass		> 99.9 MΩ	4VA	Pass
ABC INFLATABLES	CT93DT	119	PSU	30/11/2021	Fail				Fail
ABC INFLATABLES	CT93DT	120	EXT LEAD	30/11/2021	Pass	0.14 Ω	> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT93DT	121	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	122	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	123	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	124	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	125	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	126	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	127	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	128	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	129	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	130	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	131	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	132	EXT LEAD	30/11/2021	Pass	0.37 Ω	> 99.9 MΩ	Normal	Pass
ABC INFLATABLES	CT93DT	133	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	134	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	135	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	136	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	137	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	138	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	139	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	140	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	141	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	142	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	143	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	144	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	145	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	146	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	147	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	148	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	149	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	150	16A LEAD	30/11/2021	Fail				Fail
ABC INFLATABLES	CT93DT	151	32A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	152	32A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	153	32A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	154	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass
ABC INFLATABLES	CT93DT	155	16A LEAD	30/11/2021	Pass		> 99.9 MΩ		Pass

ABC INFLATABLES	CT93DT	156	BATTERY CHARGER	30/11/2021	Pass		> 99.9 MΩ		44VA	Pass
ABC INFLATABLES	CT93DT	157	BLOWER	30/11/2021	Pass		3.4 MΩ	1.42 mA	2133VA	Pass
ABC INFLATABLES	CT93DT	158	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.16 mA	1390VA	Pass
ABC INFLATABLES	CT93DT	159	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	160	32A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	161	PSU	30/11/2021	Pass		> 99.9 MΩ		0VA	Pass
ABC INFLATABLES	CT93DT	162	PSU	30/11/2021	Pass		> 99.9 MΩ		0VA	Pass
ABC INFLATABLES	CT93DT	163	PSU	30/11/2021	Pass		> 99.9 MΩ		0VA	Pass
ABC INFLATABLES	CT93DT	164	EXT LEAD	30/11/2021	Pass	0.09 Ω	> 99.9 MΩ			Normal
ABC INFLATABLES	CT93DT	165	EXT LEAD	30/11/2021	Pass	0.11 Ω	> 99.9 MΩ			Normal
ABC INFLATABLES	CT93DT	166	EXT LEAD	30/11/2021	Pass	0.28 Ω	> 99.9 MΩ			Normal
ABC INFLATABLES	CT93DT	167	EXT LEAD	30/11/2021	Pass	0.34 Ω	> 99.9 MΩ			Normal
ABC INFLATABLES	CT93DT	168	ADAPTOR	30/11/2021	Pass	0.18 Ω	> 99.9 MΩ			Normal
ABC INFLATABLES	CT93DT	169	ROUTER	30/11/2021	Pass		> 99.9 MΩ		3VA	Pass
ABC INFLATABLES	CT93DT	170	PSU	30/11/2021	Pass		> 99.9 MΩ		0VA	Pass
ABC INFLATABLES	CT93DT	171	PSU	30/11/2021	Pass		> 99.9 MΩ		0VA	Pass
ABC INFLATABLES	CT93DT	172	PSU	30/11/2021	Pass		> 99.9 MΩ		0VA	Pass
ABC INFLATABLES	CT93DT	173	CHARGER	30/11/2021	Pass		> 99.9 MΩ		0VA	Pass
ABC INFLATABLES	CT93DT	174	PRINTER	30/11/2021	Pass		> 99.9 MΩ		14VA	Pass
ABC INFLATABLES	CT93DT	175	AC LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	176	SEWING MC	30/11/2021	Pass		> 99.9 MΩ	< 0.10 mA	0VA	Pass
ABC INFLATABLES	CT93DT	177	FAN	30/11/2021	Pass		> 99.9 MΩ	< 0.10 mA	11VA	Pass
ABC INFLATABLES	CT93DT	178	EXT LEAD	30/11/2021	Pass	0.15 Ω	> 99.9 MΩ			Normal
ABC INFLATABLES	CT93DT	179	BLOWER	30/11/2021	Pass		94.07 MΩ	0.16 mA	1413VA	Pass
ABC INFLATABLES	CT93DT	180	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	181	16A LEAD	30/11/2021	Fail					Fail
ABC INFLATABLES	CT93DT	182	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	183	EXT LEAD	30/11/2021	Pass	0.35 Ω	> 99.9 MΩ			Normal
ABC INFLATABLES	CT93DT	184	EXT LEAD	30/11/2021	Pass	0.3 Ω	> 99.9 MΩ			Normal
ABC INFLATABLES	CT93DT	185	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.24 mA	1860VA	Pass
ABC INFLATABLES	CT93DT	186	EXT LEAD	30/11/2021	Pass	0.35 Ω	72.64 MΩ			Normal
ABC INFLATABLES	CT93DT	187	EXT LEAD	30/11/2021	Pass	0.35 Ω	> 99.9 MΩ			Normal
ABC INFLATABLES	CT93DT	188	16A ADAPTER	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	189	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	190	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	191	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	192	BLOWER	30/11/2021	Pass		1.63 MΩ	0.89 mA	2668VA	Pass
ABC INFLATABLES	CT93DT	193	BLOWER	30/11/2021	Pass		> 99.9 MΩ	< 0.10 mA	2447VA	Pass
ABC INFLATABLES	CT93DT	194	BLOWER	30/11/2021	Pass		> 99.9 MΩ	0.14 mA	1189VA	Pass

ABC INFLATABLES	CT93DT	195	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	196	LIGHT	30/11/2021	Fail					Fail
ABC INFLATABLES	CT93DT	197	EXT LEAD	30/11/2021	Pass	0.15 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	198	EXT LEAD	30/11/2021	Pass	0.15 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	199	EXT LEAD	30/11/2021	Pass	0.26 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	200	PSU	30/11/2021	Pass		> 99.9 MΩ		OVA	Pass
ABC INFLATABLES	CT93DT	201	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	202	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	203	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	204	BLOWER	30/11/2021	Pass		> 99.9 MΩ		3259VA	Pass
ABC INFLATABLES	CT93DT	205	BLOWER	30/11/2021	Pass		16.71 MΩ	0.26 mA	1253VA	Pass
ABC INFLATABLES	CT93DT	206	EXT LEAD	30/11/2021	Pass	0.43 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	207	EXT LEAD	30/11/2021	Pass	0.31 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	208	EXT LEAD	30/11/2021	Pass	0.36 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	209	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	210	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	211	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	212	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	213	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	214	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	215	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	216	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	217	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	218	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	219	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	220	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	221	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	222	16A LEAD	30/11/2021	Pass		> 99.9 MΩ			Pass
ABC INFLATABLES	CT93DT	223	EXT LEAD	30/11/2021	Pass	0.44 Ω	> 99.9 MΩ		Normal	Pass
ABC INFLATABLES	CT93DT	224	RODENT DETERANT	30/11/2021	Pass		> 99.9 MΩ		15VA	Pass
ABC INFLATABLES	CT93DT	225	SPEAKER	30/11/2021	Pass		> 99.9 MΩ		20VA	Pass